

# General Capacity Investigation Oregon PUC

## Phase I Workshop: What is Capacity

June 14, 2019

John Fazio

NW Power and Conservation Council

# Outline

- Energy, Capacity and Flexibility
- Hydroelectric sustained-peaking capability
- Associated System Capacity Contribution (ASCC)
- Adequacy Reserve Margin (ARM)
- Validation of ARMs and ASCCs
- Optional:  
Why solar ASCC is so much higher than its standalone capacity value for the PNW power supply



# General Definitions

- **Energy** = Quantity  
Measured in megawatt-hours or  
average megawatts (1 aMW = 8,760 MW-hrs)
- **Capacity** = Rate of producing energy  
Measured in megawatts
- **Flexibility** = Ramping capability  
The ability of the power system to continuously match  
generation to system demands



# Another way to think about it

- **Energy** equates to fuel  
Must have sufficient fuel to meet the highest expected annual average energy demand
- **Capacity** equates to machines  
Must have sufficient machine capability to meet the highest expected hourly demand
- **Flexibility** = equates to ramping  
Must have sufficient machine flexibility to increase or decrease generation moment by moment to balance within-hour scheduling mismatches



# Capacity of Hydroelectric Systems

(with limited storage)

- **Single-Hour Capacity**

- Maximum power capability during peak-demand hour
- Single-hour hydro capacity = 34,222 MW
- Cannot be sustained over a cold snap or heat wave


- **Sustained-Peak Capacity**

- Maximum average power capability during a limited number of peak-demand hours
- Sustained-peak hydro capability ~ 23,000 MW<sup>1</sup>
- Can be sustained over a cold snap


<sup>1</sup>For 6 peak hours/day in January during the lowest runoff water year



# Sustained-Peak Capacity varies by Month, Water Condition and Duration of Peak



# Sustained-Peak Capacity varies by Month, Water Condition and Duration of Peak



# Standalone Capacity vs. Net System Capacity

- **Standalone capacity** is the percentage of nameplate capacity that can be counted on with no interaction with available storage (i.e. hydroelectric system)
- **Net system capacity** is the percentage of nameplate capacity that can be counted on when allowed to interact with storage facilities (i.e. hydroelectric system)





# Power Plan Adequacy Requirements (ARM and ASCC)

- The **Adequacy Reserve Margin** (ARM) is the amount of surplus capacity (or energy) needed, over the expected weather-normalized peak load (or average load), to ensure adequacy, in units of percent of expected load.
- The ARM is used in the Regional Portfolio Model as the adequacy test for resource buildouts.
- The **Associated System Capacity Contribution** (ASCC) is the net firm capacity gained when a resource is added to a power supply with storage, in units of percent of nameplate capacity.
- ASCC values are used to calculate ARMs and to assess if a power supply meets the ARM standard.




# Associated System Capacity Contribution

- ASCC is the net firm capacity gained when a resource is added to a power supply with storage (e.g. hydroelectric system).
- During off-peak hours (conditions allowing), the added resource can be operated to replace hydro generation, which saves water
- Saved water translates into added hydro capacity
- $ASCC = \text{Resource's stand-alone capacity} + \text{Added hydro capacity}$



# Hydro Capacity Gained with New Resource

## Using Hydro Storage to Increase Capacity




# Calculating ASCC

1. Base case:  
Begin with an inadequate supply (i.e. LOLP  $\gg$  5%)
2. Determine how much “perfect” capacity is needed to reduce LOLP to 5% (cap-need-base)
3. Study case:  
Add a new resource (with nameplate-capacity)
4. Determine how much “perfect” capacity is needed to reduce LOLP to 5% (cap-need-study)
5.  $ASCC = \frac{\text{cap-need-base} - \text{cap-need-study}}{\text{nameplate-capacity}}$




# Peak-Hour Curtailment Duration Curve

(Largest hour curtailment per game, sorted highest to lowest)




# Peak-Hour Curtailment Duration Curve

(Same as before but LOLP on x-axis)



# Peak-Hour Curtailment Duration Curve

(Same as before but LOLP on x-axis)



Adding a 400 MW resource is equivalent to adding 500 MW of “perfect” capacity to the curtailment curve, thus  
 $ASCC = 500/400 = 125\%$



# ASCC Values (%) from the 7<sup>th</sup> PPlan<sup>1,2</sup>

Resource	Fall	Winer	Spring	Summer
Solar PV	26	81	81	42
Energy Efficiency	124	101	114	116
Wind	3	11	11	8
Gas-Fired Turbine	128	100	102	120
Geothermal	128	100	102	120

<sup>1</sup>The net gain in peaking capability should be attributed to the hydro system.

<sup>2</sup>Incremental capacity gains diminish as more resource is added.





# ASCC vs. ELCC

- The **ASCC** is essentially the same as the Effective Load Carrying Capability (ELCC)
- The Council chose to use a different name because of the way in which it calculates ASCC
- **ELCC** is more typically calculated using Expected Unserved Energy (EUE) instead of using the curtailment duration curve
- ELCC is more precise because it accounts for all shortfall hours but it takes longer to assess (more iterations)
- ASCC is faster and is sufficient for the analytical tools used to develop the power plan



# Calculating ELCC using EUE

- Begin with an adequate power supply (however it is defined)
- Record the EUE
- Add an increment of load and record the increase in peak hour load
- The resulting EUE is larger because the new system (with higher load) becomes less adequate
- Add increments of new resource until the EUE matches the original EUE (for an adequate supply)
- The ELCC (in units of percent) tells us how much peak load each unit of new resource can serve without affecting adequacy
- Example: If ELCC is 10% then 100 MW of resource can serve 10 MW of peak load adequately

- $$ELCC = 100 \times \frac{\text{increase in peak load}}{\text{added nameplate capacity}}$$



# Adequacy Reserve Margin

- The Adequacy Reserve Margin (ARM) is the amount of surplus capacity (or energy) needed, over the expected weather-normalized peak load (or average load), to ensure adequacy.
- The Council's 5% Loss-of-Load-Probability (LOLP) standard is translated into an Adequacy Reserve Margin (ARM).
- Seasonal (quarterly) ARM's are used in the Council's Regional Portfolio Model to ensure that resulting resource strategies yield adequate future power supplies.



# Calculating ARMs

- The **capacity ARM** is calculated by subtracting the expected peak load from the aggregate capacity of a system whose LOLP is exactly 5%, divided by the load.
- The **energy ARM** is calculated by subtracting the expected average load from the aggregate average generating capability of a system whose LOLP is 5%, divided by the load.
- Aggregate capacity takes ASCC values into account, which include forced outage rates and maintenance.
- Expected peak and average loads are weather-normalized
- $ARM_E$  (energy) = (average capability – average load)/average load
- $ARM_C$  (capacity) = (peaking capacity – peak load)/peak load



# ARM<sub>C</sub> (Capacity)

(Based on a power supply just at a 5% LOLP)

Resource Type	Adequacy Reserve Calc	Value (MW)
Thermal	Nameplate	15,000
Wind	ASCC value of 5%	250
Hydro	Lowest 10-hr sustained peak	20,625
Solar	ASCC value of 25%	125
Imports	Max per hour	2,500
<b>Total Resource</b>		<b>38,500</b>
Load	Peak-hour Load	35,000
<b>ARM Capacity</b>	<b>(Resource - Load)/Load</b>	<b>10%</b>



# Example of How the $ARM_C$ Works

For a Future Operating Year	
Peaking capability	41,000 MW
Peak load	39,000 MW
Implied adequacy reserve	$(41,000 - 39,000) / 39,000 = 5\%$
ARM Capacity Requirement	10%
<b>Assessment:</b>	<b>System is inadequate</b>
<b>Action:</b>	<b>More resource needed</b>
Resource need = (ARM * Load) + Load	$(0.1 * 39,000) + 39,000 = 42,900$ MW
Incremental resource need = Resource need - peaking capability	$42,900 - 41,000 = 1,900$ MW

For this example, to meet the 10% ARM requirement, an additional 1900 MW of capacity must be added to the system.



# Validating ASCC and ARMs

- From the 7<sup>th</sup> power plan, several future year resource buildouts were selected to test for adequacy
- **Goal: LOLP should be between about 2% and 5%** (i.e. to ensure an adequate but not overbuilt supply)
- For all tested years from the 7<sup>th</sup> plan output, the LOLP fell within the desired range.
- Without using the ASCC values, future resource mixes were always overbuilt (i.e. LOLP = 0%)



# Optional






# Why Solar Integrated Capacity is so much higher than its Standalone Capacity

- Simulated curtailment events range from one hour to over 24 hours
- About 1/3 of all curtailment events are 18 hours in duration (because the hydro system is used to flatten out anticipated peak hours shortfalls)
- Since solar only provides generation roughly between 7am and 7pm, not all of the 18-hour shortfall events will be satisfied
- However, when coupled with hydro storage, the combined effect can satisfy many more longer-duration curtailment events
- Example is provided in the following slides...




# Typical Shortfall Event and Solar Generation



- Some curtailments occur when solar is not generating
- As a standalone resource, surplus solar generation cannot be shifted into other hours



# Curtailment with Standalone and Integrated Solar



# Integrating Solar affects Hydro & Thermal Resources

